


Model Generalizations

- IR reflective coating on conventional walls saves cooling energy. Savings are 4% to 9% compared to non-IR reflecting walls



Model Generalizations

- IR reflective coating on CMU walls shows larger savings of cooling energy. Savings are 6% to 13% compared to cooling energy with non-IR reflecting walls

